



CROSBY INDEPENDENT SCHOOL DISTRICT

14670 FM 2100 CROSBY, TEXAS 77532

281-328-9200

Regular Agenda Item

Meeting Date	July 13, 2026
Action	Consider approval of gas line repairs in the amount of \$98,520 from Cue Construction Services, via TIPS contract #23010401.
Motion	Move to approve gas line repairs in the amount of \$98,520 from Cue Construction Services, via TIPS contract #23010401.
Administrative Recommendation	Administration recommends approval of gas line repairs, as presented.
Authority for this Action	Board Policy CH (Local): <ul style="list-style-type: none">• The Board delegates to the Superintendent or designee the authority to make budgeted purchases for goods or services. However, any single, budgeted purchase of goods or services that costs \$50,000 or more, regardless of whether the goods or services are competitively purchased, shall require Board approval before a transaction may take place.
Goal/Objective Addressed	<ul style="list-style-type: none">• Goal 7: Crosby ISD will be a good steward of taxpayers' money.• Goal 8: Crosby ISD will maintain quality and safe facilities and adequately plan for future needs.
Background	On June 15, the Board of Trustees approved gas pipe testing at all campuses to comply with requirements under Texas Utilities Code Sections 121.5005 through 121.507 and Texas Administrative Code Section 8.230. The gas pipe testing revealed leaks at Barrett Elementary School, Crosby Elementary School, Crosby Middle School, Drew Elementary School, and Newport Elementary School. The proposals from Cue Construction Services will provide repairs for all identified leaks and retesting after repairs are made.
Staffing Implications	N/A
Budget Information	2026-2027 General Fund budget will be used to cover the purchase.
Impact of this Action	Provide safe facilities for students and staff members.
Attachments	Proposals from Cue Construction Services
Resource Personnel	Robert L. Heniff, Chief Financial Officer