

Maintenance Report

March 11, 2024

Water

During the month we:

- Performed the routine monthly water test.
- Took water meter readings for the month.
- One water service shut off due to lack of payment. It is turned back on.
- We have been working on our lead and copper rule improvements.

Wastewater Treatment

During the month we:

- Completed effluent testing and delivered to the lab in Omaha.
- Electric Pump serviced the two pumps at the lift station. The impellers are worn and need to be replaced. Leadtime is up to 4-6 weeks.
- The manhole riser and sewer main has been removed and replace at 1405 Hackberry St.

Dump

- Pushed up the brush and compost pile.

Street

- H & L Asphalt is planning on doing the crack repair and sealing this month.

General

- General maintenance of all City owned properties.
- Will be starting to turn water back on at the park and ballfields.
- Power has been turned on at the south ballfield.

Sincerely
Russ Jones