

Uvalde CISD	2026					
7-7-2026						
Project type	Month					Number of completed work orders as per campus for the month
	Column2	Column3	Column4	Column5	Column6	Column 7
Work order completed for	Month		Comp. W.O.			Year 2026
Anthon School- Uvalde Dual Language Academy	June		15			
Batesville School	June		19			
Benson-Crossroads Academy	June		13			
Dalton School	June		12			
Flores Complex	June		27			
Uvalde High School (including tennis complex)	June		29			
Morales Junior High	June		33			
Praxedis Mata Torres-West Garden School	June		1			
UCISD Administrative Complex	June		19			
Slate Creek	June		6			
Athletic Fields	June		2			
Honey Bowl	June		9			
Open extended work orders for yardwork.	June		912 hrs			
Food Drive assistance	June		0			
Legacy	June		6	Comp. w.o. June 191		
Year to date work orders completed			2327			
Work in Progress	Status	Cost of work	Board App.	Contractor	Date of work	Notes on projects in progress
Bad floor drain in the Cruz Gym West side north locker room	Completed	\$671	no	UCISD M&O	Completed	Busted out concrete to access drain p trap, cut and removed old padlock bodies from drain and repiped and poured concrete.
Room 18 and cafeteria units have burned out condenser fan motors	In progress	\$3,336	no	UCISD M&O	In progress	Fan motors burned out on several of the units at Benson(6 motors). Parts are now here, waiting to be installed.
Room 202 at Morales Bard unit not functioning.	In progress	?	no	UCISD M&O	In progress	New board and transformer are ordered to return a/c in room 202 to service.
Anthon cafeteria dining area a/c not working.	In progress	\$5,448	no	UCISD M&O	in progress	Compressor burned out on the dinning area a/c, new compessor, dryer and expansion being installed to return to service.
Flores Gym a/c not cooling due to refrigerant loss	Completed	\$6,066	no	Texas Air	Completed	Texas air located leeak in the unit and installed shock arrestors on refer line to prevent copper breakage in future.
RTU 2 has a bad coil and is operating at half capacity	Hold	\$27,846		Texas air	hold	RTU 2 needs a new condensor coil to return to full operating status. Awaiting decision .
Having problems with RTUs 7,11,12,15,18 at Legacy campus.	Hold	?	no	Texas Air	Hold	These units do not seam to be cooling as they should. Some units have been powered down at this time.
Deeptine airation and top dressing of Honey Bowl to prepare for season	completed	\$12,190	no	Texas MultiChem	Completed	Airation of field and top dress with 4 truck loads of sand to make field ready for 2026 football season
Mahindra Tractor at Tellus Equipment for engine problems	Quote	Awaiting Quote	no	Tellus Equipment	Quote	Motor problems with 35 horse tractor. Has been taken to Tellus Equipment for quote on repair.
Flores School Cafeteria dinning area A/C down.	In progress	?	no	Texas Chillers	in progress	Both Split systems down in cafeteria, Local company could not fix. Called Texas Chillers to come and service Units.
Make repairs to the #11 RTU not cooling in the 600 wing UHS.	In progress	parts 5947.00	no	UCISD-Texas Chillers	in progress	Electric fan motor and 1st stage compressor burned up. Parts ordered and Texas Chillers set to install.
Make repairs to drive motors at the Auditorium Stage and 2 AHU	In progress	\$261	no	UCISD M&O	in progress	Starter heater are week and letting unit shut down. New heaters on the way.
Instalation of donated water fountains at Dalton School	in progress	\$2,910	yes	UCISD M&O	in progress	Waiting for testing of wall materials and bricks as per State and Fedral requirements Safety
Southland Industries, formerly Brandt to make chiller repairs	parts ordered	\$24,768	no	Southland Ind.	parts ordered	Repairs to the Flores boiler are needed. Bad expansion valve and Pressure sensor on stage 1 are needed.
Schneider electric Led light conversion.	In Progress	\$4,000,000	yes	Schneider electric	In Progress	Conversion of lighting on selected campuses to offset the cost of BAS systems on same campuses.
Schneidr Electric BAS conversion	In Progress	Part of above	yes	Schneider electric	In Progress	Replacement of BAS controls at selected campuses to take the place of aged controls that are outdated
Start test Legacy School for Asbestos for the Abestos management plan	to begin	\$3,268	no	TASB	Make appt.	Will arrange to start testing of all materials in new school that are not solid wood, steel, or glass.
Price to rekey the Uvalde High School	Approval	\$216,422		Allegion ,Acme Hardware	Approval	Rekey of the entire UHS campus awaiting approval.
Continued repairs to the exterior Doors that may be safety hazzard.	Continuing		no	M&O UCISD	Continuing	Make repairs to the exterior doors and gates to make sure the campus stays secure, even if covered by warrenty.
Installation of key warden sysytem at campuses	training	\$48,481	no	KeyWarden Systems	Training	Lock boxes installed. The programming is to be started soon.
Check on the status of punchlist items not done at Legacy School	In Progress	?	no	UCISD M&O	in Progress	Check on list of items at the Legacy Campus that were not finished or done to satisfaction before warrenty period runs out.
Check on the status of punch list items in the vestibules at campuses	In Progress	?	no	UCISD M&O	In Progress	Check on a list of items not finished in the vestibule project or not up to standards before the warrenty period runs out.
Alphanumeric identification of campus buildings- doors-gates-windows	in progress	\$25,031	no	M&O UCISD	in progress	Identify all building- doors-gates-windows on all campuses (phase 1) building ID.
Look into price to rekey the llegacy School due to lost keyring.	in progress	?	no	UCISD M&O	in Progress	Getting prices on cost to rekey the Legacy campus due to a lost set of keys. Starting with the outer doors and gates.
WO# 73701 and 73793, secure electrical panels and disconnect boxes	in progress	\$9,786	no	M&O UCISD	in progress	Secure all electrical boxes and panels with same keyed locks district wide as per Slidesoft safety stated (one campus at a time)
Pest control cost for month (Bugco, Food Service Kitchens)		\$300	no	BUGCO	On Going	Cost of pest control in food service areas.
Pest control cost for month (Medina pest control. Non food service areas)		\$170	no	Medina Pest Control	On Going	Cost of pest control services in all other areas that are not food service kitchen related.
Door sweeps performed by Mr. Noe Truan.	In Progress		no	Noe Truan	In Progress	Mr Truan goes from campus to campus and checks doors and gates to make sure all is in proper working order, repair as needed.
Paint new doors in district. Only at times when students are on a break.	In Progress	\$1,833	no	UCISD M&O	In Progress	Clean, prime and paint the new doors at various campuses that have been installed to replace damaged doors.