

**FACILITIES/CONSTRUCTION REPORT
MAY 2026**

BHS HVAC:

5-6 Calm, warm@58 degrees. Trane troubleshooting/start-up of air handler unit #6, replace electrical harness, 1 worker.

5-7 Calm, warm@64 degrees. Trane troubleshooting/start-up of air handler unit #6, program unit for ATS heating/cooling system, 1 worker.