



## ADDENDUM

### Special School Board Meeting Tuesday, June 30, 2026 District Office 7:45 AM

---

#### VII. ACTION ITEMS

<b>1. AGENDA ITEM #1</b>
--------------------------

**Subject:** Consider Approval of High School Chiller Repair

**Action:** Requires a Motion

**Background:** In May 2026, it was discovered that the chiller system at SPHS was not functioning due to cracked underground pipes. In response, with the approval of the Business Committee, the district moved to short term fixes including renting a temporary chiller to get the building through graduation and above ground pipes to get the building through until a long term solution could be developed.

The district, in consultation with its HVAC partners, has developed a recommendation for a long term solution involving replacing the cracked underground pipes.

A recommendation will be presented at the meeting.

**Presentation:** Seth Putz, Operations and Maintenance Supervisor  
Jon Graff, Superintendent

**Options/Recommendation:** I recommend that you approve the proposed repair of the High School chiller.