

Finance Subcommittee Meeting
Wednesday, February 27, 2013 5:30 PM
Central Services

I. January Statement of Accounts

II. Re-lamping Project Authorization

III. Indoor Air Quality Report

Attachments:

Indoor Air Quality Report

2

IV. School Security Improvements

V. Salary Negotiations

VI. Other

GRANBY PUBLIC SCHOOLS
INDOOR AIR QUALITY SURVEY

SCHOOL YEAR 2012-13

School	Summary Comments	Concerns #1	Concerns #2	Concerns #3
High School	FY12: Major problems are heat related. Water leaks have been repaired.	FY12: Leaks in room 1312, 2207, 3218 – repairs are being monitored. FY13: continue to monitor repairs to 1312, 2207, and 3218. Not air quality issue yet.	FY12: Main gym dusty, especially weight room. Some improvement vs. prior year. FY13: Improved, but a constant issue with no windows that open	FY12: Girls locker room has little ventilation and is hot when temperature is 65 degrees or above FY13: Same concerns
Middle School	FY12: After surveying each faculty and staff member...relatively clean facility with good indoor air quality. FY13: Same overall comment	FY12: Delivery trucks turn off engines to avoid exhaust entering air ducts FY13: No comment on this issue.	FY12: Girls bathrooms need more ventilation. Head Custodian to address FY13: No comment on this issue	FY12: No comment on this issue FY13: Dust in Media Center carpet
Kelly Lane	FY12: Kelly Lane is in excellent shape in regards to IAQ. FY13: Air vents need attention – some not working? Many vents need cleaning of ceiling tiles near vents.	FY12: Rooms 1- 11 sometimes cold in winter FY13: Same comment – constant fresh air blowing	FY12: Odor from heating system in gym FY13: No odor comment, gym vent needs to be cleaned	FY12: Dust level high in rooms 10 & 20 FY13: Dust level high in Book & Copy room
Wells Road	FY12: Presently, there are a very small number of reported concerns by the staff FY13: Same overall comment			
Kearns	FY12: Generally satisfied with air quality; need better dusting in some areas and have heating issues. FY13: Same overall comment. A couple of moisture issues that need attention.	FY12: Room 23 has mildew smell on carpet where hot water pipe leaked. FY13: signs of moisture in room 20	FY12: No comment on this issue. FY13: exhaust fans in office bathroom and clinic not functioning properly	FY12: A number of rooms need more frequent dusting. FY13: Dusting skipped in some rooms and needed on library shelves